

## CITY OF PRINCE ALBERT BYLAW NO. 35 OF 2001

*A Bylaw of The City of Prince Albert to  
amend the Connections Bylaw, being  
Bylaw No. 12 of 1995, as amended.*

WHEREAS it is deemed expedient to further amend the Connections Bylaw, being Bylaw No. 12 of 1995, as amended with respect to service water connections;

NOW THEREFORE, THE COUNCIL OF THE CITY OF PRINCE ALBERT IN OPEN MEETING ASSEMBLED ENACTS AS FOLLOWS:

1. Subsection 10(2) is hereby deleted and the following substituted therefor:
  10. "(2) *A water service connection for a single-family residential use shall not be less than 25mm (1 inch) in diameter and shall be copper with brass fittings or such other material approved by the City Engineer. The size, material and specifications of the water service connection for any other use shall be specified by the owner on his application and shall comply with the requirements of the Regulations and other applicable provincial and federal law. Sizes, materials and specifications not governed by the Regulations or other provincial or federal law shall be to such specifications as may be approved by the City Engineer.*"
2. This Bylaw shall come into force and take effect on, from and after the final passing thereof.

INTRODUCED AND READ A FIRST TIME THIS 4th DAY OF June ,A.D. 2001.  
READ A SECOND TIME THIS 4th DAY OF June ,A.D. 2001.  
READ A THIRD TIME AND PASSED THIS 4th DAY OF June ,A.D. 2001.

  
MAYOR

  
CITY CLERK

BYLAW NO. 35 OF 2001

PAGE 1 OF 1

APPROVED BY THE PRINCE ALBERT HEALTH DISTRICT UNDER THE PROVISIONS OF SUBSECTION 50(2) OF THE PUBLIC HEALTH ACT, 1994 UNDER DATE OF JUNE 26, 2001.

APPROVED BY PUBLIC HEALTH, SASKATCHEWAN HEALTH UNDER THE PROVISIONS OF SUBSECTION 50 (1) OF THE PUBLIC HEALTH ACT UNDER DATE OF JULY 17, 2001.